

水質・水温データ（し尿第1施設）（平成28年度実績）

月	日	曝気槽									第2沈殿槽	
		水温(℃)		pH		MLSS(mg/l)		DO(mg/l)		SV (%)	透視度 (度)	pH
		入口	出口	入口	出口	入口	出口	入口	出口			
12	2	15.7	15.3	5.2	5.0	2,310	1,860	7.1	7.0	8	2	5.2
	5	14.8	14.7	5.1	4.9	1,650	1,320	7.2	6.7	8	3	5.4
	7	13.7	13.8	5.8	5.7	1,670	1,500	6.8	6.9	8	3	5.8
	9	13.7	13.6	6.0	5.9	1,720	1,500	1.4	4.3	4	3	5.9
	12	13.9	13.7	5.5	5.5	1,940	1,790	6.6	6.7	3	3	5.6
	14	13.7	13.7	5.6	6.7	2,000	1,770	7.4	7.1	4	4	5.5
	16	13.3	13.3	5.7	5.5	2,080	1,900	6.8	6.8	5	4	5.8
	19	14.7	14.4	5.6	6.4	2,940	2,570	5.9	5.4	9	3	5.6
	21	14.8	14.7	5.7	5.5	3,470	3,210	5.9	5.5	8	0	3.0
	26	15.0	14.8	5.4	5.4	2,050	2,000	5.9	5.9	1	4	5.7
	28	14.1	14.1	5.9	5.9	1,780	1,770	4.9	4.9	0	5	5.9
1	4	14.9	14.8	5.7	5.7	2,420	2,240	4.5	4.6	4	8	5.7
	6	13.3	13.4	5.8	5.8	2,130	2,060	4.8	4.7	1	9	5.8
	10	13.5	13.6	6.1	6.2	1,860	1,840	8.9	8.9	1	10	6.0
	11	13.2	13.4	6.1	6.2	1,920	1,870	9.4	6.8	0	7	6.1
	13	12.4	12.6	6.3	6.5	1,700	1,690	9.4	8.0	0	9	6.2
	16	8.9	12.2	6.3	6.5	2,020	1,890	9.0	9.0	1	12	6.4
	18	12.3	12.6	6.5	6.6	-	-	2.3	2.8	0	11	6.3
	20	12.2	12.4	6.5	6.5	-	-	7.1	7.0	0	10	6.4
	23	12.5	12.6	6.2	6.3	2,410	2,050	7.8	6.8	9	11	6.1
	25	12.0	12.2	6.2	6.3	1,500	1,350	2.0	6.6	8	7	6.2
	27	12.0	12.3	6.6	6.3	1,320	1,180	4.9	4.6	7	7	6.3
	30	12.3	12.7	6.0	5.9	1,170	1,080	6.6	6.2	5	8	5.7
2	1	12.3	12.5	5.9	6.0	1,390	1,130	6.6	6.2	5	5	6.0
	3	11.7	11.5	6.1	6.1	1,680	1,420	9.4	9.1	4	3	6.2
	6	12.6	12.6	6.0	6.0	1,690	1,680	8.9	8.4	3	5	6.0
	8	11.5	11.6	6.3	6.3	1,500	1,410	5.6	8.2	1	6	6.3
	10	12.0	12.0	6.3	6.3	1,040	980	8.5	8.0	2	5	6.2
	13	11.8	12.0	6.3	6.4	1,520	1,480	8.4	8.0	1	4	6.4
	15	12.0	12.0	6.5	6.6	1,240	1,240	8.0	8.8	0	8	6.5
	17	12.0	12.2	6.6	6.7	1,600	1,590	8.0	8.8	0	6	6.6
	20	17.5	17.5	6.4	4.6	1,620	1,590	11.5	11.4	0	5	6.7
	22	11.4	11.5	6.8	6.9	1,630	1,660	10.6	10.9	0	6	6.8
	24	10.9	11.7	6.9	6.9	1,200	1,190	10.1	11.2	0	6	6.9
	27	12.1	12.1	6.7	6.8	1,400	1,380	11.5	11.7	0	5	6.8