

水質・水温データ（し尿第2施設）（平成28年度実績）

月	日	曝気槽									第2沈殿槽	
		水温(℃)		pH		MLSS(mg/l)		DO(mg/l)		SV (%)	透視度 (度)	pH
		入口	出口	入口	出口	入口	出口	入口	出口			
12	2	19.0	18.9	5.3	4.8	600	1,090	7.4	6.6	4	4	4.7
	5	19.0	19.1	5.1	4.6	1,560	1,810	6.3	9.3	8	7	4.8
	7	19.2	19.1	4.9	4.4	1,680	1,490	6.5	7.1	7	36	4.5
	9	19.1	19.1	4.8	4.4	1,000	1,550	6.2	6.9	3	22	4.4
	12	19.2	19.2	4.8	4.3	1,950	2,390	5.8	6.5	8	8	4.4
	14	19.1	18.9	4.8	4.4	2,060	1,710	6.0	6.1	8	25	4.4
	16	19.1	19.1	4.8	4.4	2,030	1,840	5.9	6.6	10	19	4.5
	19	19.2	19.2	4.8	4.4	2,830	2,710	6.0	6.7	10	5	4.5
	21	19.2	19.2	4.9	4.4	3,460	3,550	5.9	6.8	11	12	4.5
	26	19.7	19.9	4.6	4.0	3,460	3,490	5.8	6.6	10	5	4.0
	28	19.1	19.2	4.1	3.7	2,450	2,800	4.8	5.2	10	15	3.9
1	4	18.8	18.9	4.2	3.8	3,230	3,710	4.6	4.9	11	5	4.0
	6	18.5	18.3	4.3	4.0	2,610	2,530	4.6	4.7	7	20	4.1
	10	18.1	18.1	4.5	4.2	1,930	2,350	8.3	9.1	1	8	4.3
	11	18.0	18.0	4.5	4.2	2,330	2,000	8.8	8.9	1	30	4.3
	13	17.8	17.8	4.8	4.8	1,750	1,740	8.9	9.0	3	38	4.5
	16	17.2	17.5	4.9	4.5	1,510	1,650	8.6	8.8	2	10	4.7
	18	17.5	17.4	4.9	4.6	680	450	8.4	6.5	2	28	4.8
	20	17.3	17.3	5.0	4.5	380	420	7.9	6.0	5	23	4.7
	23	17.0	17.2	4.5	4.4	2,460	2,310	7.8	6.5	2	7	4.5
	25	16.7	16.8	5.0	4.6	1,380	1,120	4.2	3.0	4	10	4.7
	27	16.4	16.5	5.4	5.3	1,320	1,150	4.3	4.8	4	8	5.5
	30	16.5	16.5	5.6	5.5	1,790	1,630	6.6	6.7	5	5	5.7
2	1	16.6	16.5	5.2	5.1	2,050	1,910	6.6	6.7	6	3	5.4
	3	16.2	16.4	5.3	5.0	2,080	2,160	8.3	9.0	5	3	5.3
	6	16.2	16.4	4.7	4.5	1,920	2,830	8.5	8.9	5	2	4.8
	8	15.9	15.9	4.2	4.1	2,200	2,000	9.4	9.8	2	3	4.2
	10	15.8	15.8	4.2	4.1	1,530	1,690	9.8	10.1	2	3	4.1
	13	15.5	15.7	4.4	4.3	4,290	3,900	9.7	9.9	9	2	4.2
	15	15.4	15.5	4.5	4.4	3,020	3,260	9.5	8.5	6	3	4.5
	17	15.4	15.4	4.8	4.7	3,220	3,170	9.5	8.5	4	2	4.8
	20	14.7	12.0	5.9	6.5	3,390	3,200	9.9	11.0	14	1	6.6
	22	15.1	15.1	6.1	6.4	2,820	2,670	7.9	10.1	6	6	6.3
	24	15.3	15.3	6.3	6.4	2,300	2,110	14.7	14.7	5	3	6.4
	27	15.2	15.2	5.8	5.6	2,610	2,460	10.5	11.0	5	4	5.8